

Summary of LGS special spill operation for adult passage, as coordinated at TMT Monday, 6/5

Effective Tuesday, June 6 and Wednesday, June 7:

4am – 10am:

- Spill 30% of total project outflow.
- Turbine operations maintained as constant as possible at all available units.
- LGS forebay will fill above the Minimum Operating Pool (MOP) range of 633-634 ft (amount will depend on observed inflow).

10am – 4pm:

- Pass inflow (inflow = outflow).
- Rolling two-unit outage to clean screens (may last until 5pm, depending on debris loads)

4pm – 4am:

- Increase project outflow to draft back to MOP range 633-634 ft.
- Spill will not exceed 140 kcfs as a hard constraint to avoid exceeding 130% TDG in the LGS tailrace. If inflows are higher than forecasted, or if there are unforeseen unit outages, the LGS pool may not be drafted back to the MOP range during this time period.