

September 23, 2020

Summary of Little Goose Dam operations on Tuesday, September 22, 2020

http://pweb.crohms.org/dd/nwdp/project_hourly/webexec/rep?r=lgs&date=9/22/2020

1. Hour Ending 0100 to 0500.

Generation ranging from 16.7 to 15.2 kcfs by Unit 1.

Transmission Line. In Service.

Transformer 1 (Units 1-4). In Service.

Transformer 2 (Units 5-6). Out of service.

2. Hour Ending 0600 to 1700.

Generation for station service was provided by Unit 4 (5 kcfs).

Transmission Line. Out of Service.

Transformer 1. Out of Service.

Transformer 2. Out of Service.

3. Hour Ending 1800 to 2400.

Generation 16.5 to 36.3 kcfs was provided by Units 1 and 2.

Transmission Line. In Service.

Transformer 1. In Service.

Transformer 2. On standby while transformer oil comes up to operating temperature.