

SPILL PRIORITY LIST - Effective September 1 through December 31, 2014.

LEVEL 1 – up to the 110% TDG STANDARD¹		
PRIORITY ORDER	PROJECT	SPILL ESTIMATE (KCFS)
01	BON	70
02	TDA	45
03	JDA	20
04	MCN	48
05	IHR	25
06	LMN	18
07	LGS	18
08	LWG	20
09	DWR	35% of total flow
10	CHJ	25
11	GCL	0 (OT) or 5 (DG) ²

LEVEL 2 – up to 115% TDG		
PRIORITY ORDER	PROJECT	SPILL ESTIMATE (KCFS)
01	BON	100
02	TDA	60
03	JDA	80
04	MCN	80
05	IHR	35
06	LMN	23
07	LGS	23
08	LWG	30
09	CHJ	61
10	GCL	5 (OT) or 10 (DG) ²

LEVEL 3 – up to 120% TDG		
PRIORITY ORDER	PROJECT	SPILL ESTIMATE (KCFS)
01	BON	140
02	TDA	135
03	JDA	144
04	MCN	140
05	IHR	75
06	LMN	44
07	LGS	52
08	LWG	45
09	CHJ	150
10	GCL	10 (OT) or 15 (DG)

LEVELS 4-7 (125%, 127%, 130%, and 135% TDG, respectively): Same project Priority Order as in Level 3.

¹ Outside of Fish Passage Season, the Clean Water Act standard for total dissolved gas (TDG) is ≤110% at all projects.

² Spill at GCL is either through the outlet tubes (OT) or the drum gates (DG), depending on reservoir elevation. Spill through the OT produces more TDG.