

## SPILL PRIORITY LIST – Summer 2021 (July 14 through no later than August 31)

The Spill Priority List (SPL) defines how *Lack of Load* spill will be distributed to projects in order to manage TDG on a system-wide basis. In the event of spill due to Lack of Load, spill will occur at projects in the following sequential priority order at the spill level defined for incrementally higher levels of TDG.

Level	Priority Order	Project	TDG (%)	Example Spill Level (kcfs)
<b>LEVEL 1</b> Spill level estimated to meet but not exceed the Water Quality Standard. <sup>1</sup>	1	IHR	120% / 115%	80
	2	MCN	120% / 115%	180
	3	JDA	120% / 115%	130
	4	TDA	120% / 115%	85
	5	LMN-Uniform	120% / 115%	30
	6	BON	120% / 115%	145
	7	CHJ	110%	25
	8	GCL	110%	Outlet Tubes=0; Drum Gates=5
	9	LGS	120% / 115%	30
	10	LWG	120% / 115%	40
	11	DWR	110%	35% of project outflow
<b>LEVEL 2</b> Spill level estimated to meet but not exceed daily TDG threshold.	12	IHR	120%	80
	13	MCN	120%	180
	14	JDA	120%	130
	15	TDA	120%	120
	16	LMN-Uniform	120%	52
	17	BON	120%	145
	18	CHJ	120% / 115%	65
	19	GCL	115%	Outlet Tubes=0; Drum Gates=10
	20	LGS	120%	53
	21	LWG	120%	53
<b>LEVEL 3</b> Spill level estimated to meet but not exceed daily TDG threshold.	22	IHR	122%	98
	23	MCN	122%	200
	24	JDA	122%	180
	25	TDA	122%	175
	26	LMN-Uniform	122%	56
	27	BON	122%	150 <sup>2</sup>
	28	CHJ	120%	120
	29	GCL	120%	Outlet Tubes=0; Drum Gates=20
	30	LGS	122%	56
	31	LWG	122%	63
<b>LEVELS 4 and up</b>	Same Priority Order as Level 3			

<sup>1</sup> The TDG standard (also referred to as “Gas Cap”) is ≤110% in all project tailraces except during spill for fish passage at lower Columbia and lower Snake projects. The TDG water quality standards are described in the Fish Operations Plan.

<sup>2</sup> Fish passage or lack of market spill at Bonneville Dam should not exceed 150 kcfs due to stilling basin erosion concerns.